

NATIONS UNIES
COMMISSION ECONOMIQUE
POUR L'EUROPE

ОБЪЕДИНЕННЫЕ НАЦИИ
ЭКОНОМИЧЕСКАЯ КОМИССИЯ
ДЛЯ ЕВРОПЫ

UNITED NATIONS
ECONOMIC COMMISSION
FOR EUROPE

SEMINAIRE

СЕРМИНАР

SEMINAR



RESTRICTED

EB.AIR/SEM.2/R.79
4 April 1991

ENGLISH ONLY

Executive Body for the Convention on
Long-range Transboundary Air Pollution

Fifth Seminar on Emission Control
Technology for Stationary Sources
(Nuremberg, Germany, 10-14 June 1991)

N₂O MEASUREMENTS IN VARIOUS COMBUSTION PROCESSES 1/ 2/

Transmitted by the Government of France

(Prepared by Mr. L. GOURICHON)

1/ Topic H: Monitoring

2/ This document has been reproduced as received by the secretariat.

GE.91-40354

N2O measurements in various combustion processes

L. GOURICHON

From the time when N₂O was first implicated in the depletion of stratospheric ozone and global climate change, a large number of N₂O measurements have been carried out in fossil fuel fired power plants. At present, measurements concern mainly large power plants and new technologies used for power generation (for example, fluidized bed and circulating fluidized bed boilers). Nevertheless, development of solid fuel boilers used for the production of process steam or hot water, must be taken into account because their thermal power could reach several hundred megawatts.

This paper presents the results of pollutant (N₂O, NO_x, CO, SO₂) measurements taken in two different types of boilers : a spreader stoker and an ignifluid boiler.

Characteristics of the boilers

The spreader stoker at CERCHAR's coal research laboratory in Mazingarbe, is utilized for coal and sorbent characterization and for material improvements. With a nominal thermal power of 11 MW, it is one of the smallest units of its size range. At present, 46 are operating in France for a global thermal power output of 2096 MW, with a maximum nominal power of 120 MW.

The Ignifluid boiler is in use by the General Heating Company in Paris. It produces hot water for domestic heating. With a nominal power of 340 MW, it's the largest unit of its range.

N2O sampling and analysis

As recommended by Dr. DE SOETE, the N2O measurement apparatus is composed of :

- a stainless probe equipped with a hot filter,
- a cooler,
- a scrubber containing a solution of KOH 0.1 molar,
- (and) a sample container.

The analysis is made with a gas chromatograph equipped with a HID detector.

Measurements of CO₂, O₂, CO , SO₂ and NO_x are taken during sampling.

Results on the spreader stoker

For two different coals whose compositions are given on this transparency (n°1), N₂O and SO₂ measurements were obtained for the nominal power output and for half of it.

We can see that N₂O emissions are between 26 and 40 mg/Nm³ at 6%O₂ (normal cubic metre) and that N₂O decreases a little when the power rises in the case of the FREYMING coal. We can also see that a large quantity of fixed sulfur produces a large amount of SO₂ emissions and seems to increase N₂O emissions (the fixed nitrogen is equal for the two coals but the fixed sulfur in the US coal is twice than this of the FREYMING coal) but this increase could also be linked to the granulometry of the coal. We have not yet taken enough measurements to explain this observation.

On the second transparency (n°2), we represent N₂O and SO₂ emissions for the FREYMING coal at two different loads with and without desulfurisation.

We can see that without desulfurisation, increasing the load from 5.5 MW to 11 MW produces a small decrease in N₂O emissions but has no

influence on SO₂ emissions. With desulfurisation, SO₂ is divided by 2 at 11 MW but N₂O emissions are multiplied by 2 at the same time.

On this transparency (n°3), we can see that desulfurisation produces a decrease of NO_x emissions at 11 MW but this level is higher than without desulfurisation.

Those measurements indicate that decreasing one type of pollutant could produce an increase in another and that it's necessary to consider all the pollutants for the characterisation of power systems.


Results on the Ignifluid boiler.

For half of the nominal power (about 175 MW), N₂O emissions are between 88 and 91 mg/Nm³ at 6% O₂ with a fixed nitrogen of 1.72 %. These levels are high but they are relatively small compared with those obtained in FBC or CFBC boilers. If the evolution is the same, increasing the load to the nominal power normally produces less N₂O emissions.

We can see on the table (n°4) that the amount of NO_x and SO₂ are under the statutory level, for this load.

Conclusion


In conclusion, we can say that all the power systems must be taken into account for the total emissions level of pollutants. However these measurements show that it's possible to find combustion systems for the production of steam or hot water which are environmentally relatively benign.



Spreader stoker : influence of coal composition

- N2O : FREYMING
- SO2 : FREYMING
- N2O : U.S. COAL
- SO2 : U.S. COAL


TYPE CHARBON	U.S. Coal	FREYMING
GRANULOMETRIE	0-20	0-6
CENDRES (%)	12,56	4,1
M.V. (%)	33,1	33,6
P.C.S. (J/g)	29718	33232
P.C.I. (J/g)	28330	31903
CARBONE (%)	71,35	80,92
HYDROGENE (%)	4,89	5,09
OXYGENE (%)	7,84	7,8
AZOTE (%)	1,34	1,3
SOUFRE (%)	2,02	0,8



Spreader stoker : influence of desulphurisation

CA/S = 1,8

- N2O : WITHOUT DESULPHURISATION
- SO2 : WITHOUT DESULPHURISATION
- N2O : WITH DESULPHURISATION
- SO2 : WITH DESULPHURISATION



Spreader stoker : influence of desulphurisation

CA/S = 1,8

- N2O : WITHOUT DESULPHURISATION
- NOx : WITHOUT DESULPHURISATION
- N2O : WITH DESULPHURISATION
- NOx : WITH DESULPHURISATION

N2O MEASUREMENTS

340 MW IGNIFLUID BOILER (Babcock Entreprise)

thermal power (MW)	air exces (%)	CO2 (%)	O2 (%)	CO ppm	NOx* mgNO2/Nm3	SO2* mg/Nm3	N2O* mg/Nm3
177	37	14	5,8	84	208	1707	88
173	41	13	6,2	87	222	1634	91

X* : mg/Nm3 at 6% O2

Coal composition

M.V. (%)	30,28
Cendres (%)	12,83
H2O (%)	13,69
Carbone (%)	71,56
Hydrogène (%)	4,38
Azote (%)	1,72
PCS (J/g)	29502